Serial No:
9900348

To confirm the validity of the Registered Gas Engineer please contact Gas Safe on 0800 408 5500 or www.gassaferegister.co.uk

LEISURE INDUSTRY GAS SAFETY RECORD

This form allows for the recording of results of checks as defined by the Gas Safety (Installation and Use) Regulations. Information recorded on this form does not confirm that the installation was installed by a Gas Safe registered business or that the installation complies with relevant Building Regulations.
Chimney/flue/outlets were visually checked for adequate evacuation of combustion products. A detailed internal inspection has not been undertaken.

TRURO Heating & Plumbing

Gas Safe REGISTER

DETAILS OF REGISTERED BUSINESS	JOB ADDRESS	LANDLORD/AGENT A
Truro Heating & Plumbing Services Ltd Gas Safe Reg. No: 196272 Saltram Cottage, Tomperrow, Truro, TR3 6BE Tel. No: 01872 561460	Name: MR LANEY-DAVIS Address: HILLSIDE GOONAAN CHACEWATER Tel. No: Is Accommodation Rented? (Y/N)	Name: Address: Tel. No: No. Of Appliances Te

Satisfactory Visual Inspection (Y/N)	YES	Emergency Control Valve Accessible (Y/N)	YES	Satisfactory Gas Tightness Tes	
Connection Hoses Satisfactory (Y/N)	BUCK TANK	LPG Regulator Working Pressure (mbar)	42.2	LPG Regulator Lock Up Press	

Appliance Details

	Appliance Location	Appliance Make	Appliance Model	Appliance Type	Type of F (OF/RS/
1	GARAGE	WORCESTER	GS 30SI JUNIOR	COMBI BOILER	RS
2					
3					
4					
5					

Inspection Details

	Operating Pressure in mbar and or Heat Input in KW/Btu/h	Are Safety Devices Working? (Y/N)	Satisfactory Ventilation? (Y/N)	Flue Visual Condition (Pass/Fail/NA)	Flue Performance Checks (Pass/Fail/NA)	Combustion Analyser Reading		Appliance Serviced (Y/N)	Appliar Safe T Use (Y
						CO: CO2 Ratio	CO PPM		
1	41.2	YES	YES	PASS	PASS	.0010	111	YES	YE
2									
3									
4									
5									

	Defect(s) Identified	Warning Advice Issued? (Y/N)	Remedial Work Undertaken
1			
2			
3			
4			
5			

Received By: [signature]
Print Name: LANEY-DAVIS Date: 25/2/20.

Issued By: BAZ ID Card No: 6256765
Signature: [signature] Date: 25/2/20

Must Be Completed By:
25-3-21

Top Copy : Agent/Landlord Middle Copy: Tenant Bottom Copy: Engineer To reorder this pad visit www.gasfm.co.uk or call 0800 690 6404 ©GasFM

Gas Safe / Oftec Reg:
25.02.2020 09:
Location
TRURO HEATING/PLUMBING
System type
Combination Boiler
ARTS USED
FAN TEST
LOW FIRE
HIGH FIRE